

**QUINCY COMMUNITY SERVICES DISTRICT**  
 900 Spanish Creek Road, Quincy, CA 95971-9393  
 Office hours are 8-12 and 1-5  
 (Monday through Friday, excluding holidays)  
 Business Phone: 283-0836



**RETURN SERVICE REQUESTED**

**EMERGENCY 24-HOUR PAGER: 280-7054**

**STAFF**

Larry Sullivan, General Manager  
 Jim Doohan, Lead Operator/Lab Director  
 Mike Green, Mechanic  
 Frank Potter, Operator  
 Phil Jaramillo, Operator  
 Marilyn Thornquist, Office Manager  
 Katie Gay, Administrative Secretary  
 Jacqui Harris, Accounting Clerk  
 Danae Huffman, Lab Assistant

PRESORTED  
 FIRST CLASS  
 MAIL  
 U.S. POSTAGE  
 PAID  
 QUINCY, CA  
 Permit No. 103

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**2009 Consumer Confidence Report**

Water System Name: Quincy Community Services District Report Date: June 23, 2010

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring through December 31, 2009.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Five active groundwater sources  
 Name & location of source(s): Claremont Springs, Bellamy Well, Quincy High School Well, Coburn Well and Sunset Well. QCSD also purchases water from East Quincy Services District as needed. All sources are located in Quincy, California.

Drinking Water Source Assessment information: A source assessment was completed in September 2001. A copy can be obtained by calling the Department of Public Health at (530) 224-4800. Our sources are considered most vulnerable to the following activities not associated with any detected contaminants: managed forests, gas stations, contaminate plumes, septic systems, underground storage tanks, sewer collection systems, and agricultural/irrigation wells

Time and place of regularly scheduled board meetings for public participation: \_\_\_\_\_  
The second Thursday of each month at 900 Spanish Creek Road, Quincy, CA. at 9:00 a.m.

For more information, contact: Larry Sullivan, General Manager Phone: (530)-283-0836

***TERMS USED IN THIS REPORT:***

<p><b>Maximum Contaminant Level (MCL):</b> The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.</p> <p><b>Maximum Contaminant Level Goal (MCLG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).</p> <p><b>Public Health Goal (PHG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.</p> <p><b>Maximum Residual Disinfectant Level (MRDL):</b> The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.</p> <p><b>Maximum Residual Disinfectant Level Goal (MRDLG):</b> The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.</p>	<p><b>Primary Drinking Water Standards (PDWS):</b> MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.</p> <p><b>Secondary Drinking Water Standards (SDWS):</b> MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.</p> <p><b>Treatment Technique (TT):</b> A required process intended to reduce the level of a contaminant in drinking water.</p> <p><b>Regulatory Action Level (AL):</b> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.</p> <p><b>Variances and Exemptions:</b> Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.</p> <p><b>ND:</b> not detectable at testing limit</p> <p><b>ppm:</b> parts per million or milligrams per liter (mg/L)</p> <p><b>ppb:</b> parts per billion or micrograms per liter (ug/L)</p> <p><b>ppt:</b> parts per trillion or nanograms per liter (ng/L)</p> <p><b>pCi/L:</b> picocuries per liter (a measure of radiation)</p>
---	--

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (to be completed only if there was a detection of bacteria )	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 4	1	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	10	4.8	1	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	10	1.2	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2002-2005		2.5-30	none	none	Generally found in ground & surface water
Hardness (ppm)	2002-2005		38-110	none	none	Generally found in ground & surface water

\*Any violation of an MCL or AL is marked with an asterisk. Additional information regarding the violation is provided later in this report.

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic ppb	2-26-02 to 9-16-08		ND-2.6	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Chromium ppb	1-21-03 to 12-22-09		ND-2.4	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride ppm	12-28-00 to 12-22-09		ND-0.12	2.0	1	Erosion of natural deposits; water additive, which promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate ppm (as Nitrogen)	12-22-09		ND-5.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits.

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Color Units	12-12-05 to 9-16-08		ND-5.0	15	N/A	Naturally-occurring organic materials
Odor TON	12-12-05 to 9-16-08		ND-2.0	3	N/A	Naturally-occurring organic materials
Turbidity NTU	12-12-05 to 9-16-08		ND-0.31	5	N/A	Soil runoff
Total Dissolved Solids ppm	12-12-05		51-130	1000	N/A	Runoff/leaching from natural deposits
Specific Conductance micromhos	12-28-00 to 12-22-09		82-210	1600	N/A	Substances that form ions when in water; seawater influence
Chloride ppm	12-28-00 to 12-22-09		0.43-2.6	500	N/A	Runoff/leaching from natural deposits; seawater influence

TABLE 7 - SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	Nov. 2009	0	(0)	Human and animal fecal waste

\*Any violation of an MCL or AL is marked with an asterisk. Additional information regarding the violation is provided later in this report.